

CERTIFICATE OF CONFORMITY



- HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT PER US REQUIREMENTS**
- Certificate No:** FM22US0072
- Equipment:** 640S and 780S Mass Flow Meters
(Type Reference and Name)
- Name of Listing Company:** Sierra Instruments Inc.
- Address of Listing Company:** 5 Harris Court
Monterey, CA 93940
USA
- The examination and test results are recorded in confidential report number:

OR7A1.AE dated 24th January 1991
- FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:

Class 3600:2022, Class 3615:1989, Class 3810:1989 + S1:1995, ANSI/NEMA 250:1991
- If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.
- This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.
- Equipment Ratings:
Explosionproof for Class I, Division 1, Groups B, C and D; Dust-ignitionproof for Class II, Division 1, Groups E, F and G hazardous (classified) locations, indoors and outdoors (Type 4X).
- The marking of the equipment shall include:
Class I, Division 1, Groups B, C, D T3; Class II, Division 1, Groups E, F, G T3; Type 4X

Certificate issued by:

J.E. Marquedant

J.E. Marquedant
VP, Manager - Electrical Systems


27 September 2022

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com



SCHEDULE



US Certificate Of Conformity No: FM22US0072

12. Description of Equipment:

General - The 640S and 780S Mass Flow Meters monitor the mass flow rate of air and process gases. The mass flow probe inserts into pipes, ducts or external flows and delivers various analog output signals proportional to the gas mass flow rate.

Construction - The equipment consists of an electronics assembly, an NRTL listed electronics enclosure and a probe assembly. The probe assembly consists of a 316 stainless steel thermowell with two sensors located in the end: a velocity sensor and a temperature sensor. The probe has a maximum length of 72 inches. For probe lengths greater than 18 inches in length, an NRTL listed seal fitting is included and inserted in the probe within 18 inches of the enclosure.

Ratings - The equipment operates at 18-30 Vdc (625 mA) or 100-240 Vac, 50/60 Hz (15 W). The equipment carries a Type 4X rating.

Refer to Annex for model codes

13. Specific Conditions of Use:

None

14. Test and Assessment Procedure and Conditions:

This Certificate has been issued in accordance with FM Approvals US Certification Requirements.

15. Schedule Drawings

A copy of the technical documentation has been kept by FM Approvals.

16. Certificate History

Details of the supplements to this certificate are described below:

Date	Description
24 th January 1991	Original Issue.
27 th September 2022	<u>Supplement 4:</u> Report Reference: RR234403 dated 27 th September 2022. Description of the Change: Reissue certificate in new format. Minor model code changes and error corrections for 640S. Class 3600 and NEMA 250 updated as there are no technical changes between prior edition(s).

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

SCHEDULE



US Certificate Of Conformity No: FM22US0072

ANNEX

640S-FM-abcdefghijkl. Mass Flow Meter.

- a = Probe length: L06, L09, L13, L18, L24, L36, L42, L (var. 72 in. max.) or L-M5 (1 in. 150 lb Flange).
- b = Mounting Accessories: M0, M1, M2 (specify pipe O.D.), M1-M2 (specify pipe O.D.), M3, M4 (specify duct O.D.), M8 (duct O.D. 150psi max)
- c = Enclosure: E2 or E4.
- d = Input power: P2 or P3.
- e = Output signal: V1, V3 or V4.
- f = Display: NR, DD or DD-NRT.
- g = Gas Code: 0, 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14 or 99.
- h = Digital Communication option: pulse (not available when variable c = E2 and when variable f = NR) or MB (only available when variable d = P2).
- i = Certificate option: MC, CC, NACE, LT, PT, CO or Blank.
- j = O2 Cleaning option: O2C (Meters up to 4 inches) or Blank.

780S-FM-abcdefgh. Mass Flow Meter.

- a = Flowbody: N1, N2, N3, N4, N5, N6, N7, N8, N9, N10, F2, F3, F4, F5, F6, F7, F8, F9, F10, D4, D5, D6, D7, D8, D9, D10, GD4, GD5, GD6, GD7, GD8, GD9 or GD10.
- b = Enclosure: E2 or E4.
- c = Input power: P2 or P3.
- d = Output signal: V1, V3 or V4.
- e = Display: NR or DD.
- f = Gas Code: 0, 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 99.
- g = Digital Communication option: pulse (not available when variable c = E2 and when variable f = NR), MB (not available when variable d = P3), DP1, DP2, FF, HART (DP1, DP2, FF and HART are all available only when variable c = E2 or E4 and variable d = P2) or Blank.
- h = Certificate option: PT, CC, NC, MC or LT or Blank.

780S-FM-UHPabcdefgh Ultra High Purity. Mass Flow Meters.

- a = Mounting: BW1, VCR1, BW2, VCR2, BW4, VCR4, TR4, BW5, TR5, BW6, TR6, BW7, TR7, BW8, TR8 or BW9.
- b = Enclosure: E2 or E4.
- c = Input power: P2 or P3.
- d = Output signal: V1, V3 or V4.
- e = Display: NR or DD.
- f = Gas Code: 0, 1, 2, 6, 7, 10, 11, 99.
- g = Digital Communication option: pulse (not available when variable c = E2 and when variable f = NR), MB (not available when variable d = P3), DP1, DP2, FF, HART (DP1, DP2, FF and HART are all available only when variable c = E2 or E4 and variable d = P2) or Blank.
- h = Certificate option: PT, CC, NC, MC or LT or Blank.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com