



1. EU-TYPE EXAMINATION CERTIFICATE

2. Equipment or Protective systems intended for use in Potentially Explosive Atmospheres - Directive 2014/34/EU

3. EU-Type Examination Certificate No: FM23ATEX0041X

4. Equipment or protective system: (Type Reference and Name) 645S, 745S and TM100 Series Thermal Mass Gas Flow Meter and Temperature Transmitter

5. Name of Applicant: Sierra Instruments Inc

6. Address of Applicant 20 Ryan Ranch Road, Ste 109, Monterey, California 93940, United States of America

7. This equipment or protective system and any acceptable variation thereto is specified in the schedule to this certificate and documents therein referred to.

8. FM Approvals Europe Ltd, notified body number 2809 in accordance with Article 17 of Directive 2014/34/EU of 26 February 2014, certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential report number:

PR466793 dated 18th September 2023

9. Compliance with the Essential Health and Safety Requirements, with the exception of those identified in item 15 of the schedule to this certificate, has been assessed by compliance with the following documents:

EN IEC 60079-0:2018, EN 60079-1:2014, EN 60079-31:2014, EN 60529:1991+A1:2000+A2:2013

10. If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.

11. This EU-Type Examination certificate relates only to the design, examination and tests of the specified equipment or protective system in accordance to the directive 2014/34/EU. Further requirements of the Directive apply to the manufacturing process and supply of this equipment or protective system. These are not covered by this certificate.

12. The marking of the equipment or protective system shall include:



II 2 G Ex db IIB+H₂ T4 Gb Ta = -40°C to +70°C

II 2 D Ex tb IIIC T135°C Db Ta = -40°C to +70°C

Certificate issued by:

Certification Manager, FM Approvals Europe Ltd.

Date 15 April 2025

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals Europe Ltd. One Georges Quay Plaza, Dublin. Ireland. D02 E440
T: +353 (0) 1761 4200 E-mail: atex@fmaprovals.com www.fmaprovals.com

F ATEX 020 (Jul/2024)



Page 1 of 4

SCHEDULE

EU-Type Examination Certificate No. FM23ATEX0041X

13. Description of Equipment or Protective System:

General - The 645S, 745S and TM100 Series Thermal Mass Gas Flow Meter and Temperature Transmitters are used for measuring the mass flow of gases as well as the process gas temperature all in one package. The flowmeters are available for inline or insertion applications. The product features 4-20mA and/or pulse outputs and is also available with an optional display/configuration panel. Digital communications options include USB, HART and RS485 Modbus.

Construction - The 645S, 745S and TM100 Series Thermal Mass Gas Flow Meter and Temperature Transmitter consists of a single compartment electronics housing with thread-on window cover and a probe inserted through the housing base forming a cylindrical joint. The enclosure is provided with two (2) ¾ inch NPT openings.

Ratings - The 645S, 745S and TM100 Series Thermal Mass Gas Flow Meter and Temperature Transmitters operate at 12-28 Vdc (6W). The transmitters are rated for use in an ambient temperature range of -40°C to +70°C. The transmitter probes are rated for use in a process temperature range of -40°C to +121°C at a maximum pressure of 740 psi.

The enclosures have an ingress protection rating of IP66/67.

Refer to the Annex for model codes.

14. Specific Conditions of Use:

1. The flamepaths of the equipment are not intended to be repaired. Consult the manufacturer if repair of the flamepath joints is necessary.
2. Refer to the manufacturer's instructions to reduce the potential of an electrostatic charging hazard on the equipment enclosure.

15. Essential Health and Safety Requirements:

The relevant EHSRs that have not been addressed by the standards listed in this certificate have been identified and assessed in the confidential report identified in item 8.

16. Test and Assessment Procedure and Conditions:

This EU-Type Examination Certificate is the result of testing of a sample of the product submitted, in accordance with the provisions of the relevant specific standard(s), and assessment of supporting documentation. It does not imply an assessment of the whole production.

Whilst this certificate may be used in support of a manufacturer's claim for CE Marking, FM Approvals Europe Ltd accepts no responsibility for the compliance of the equipment against all applicable Directives in all applications.

This Certificate has been issued in accordance with FM Approvals Europe Ltd's ATEX Certification Scheme.

17. Schedule Drawings

A list of the significant parts of the technical documentation is annexed to this certificate and a copy has been kept by the Notified Body. The documents are maintained under project 3052981.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

SCHEDULE

EU-Type Examination Certificate No. FM23ATEX0041X

18. Certificate History

Details of the supplements to this certificate are described below:

Date	Description
21 September 2023	Original Issue.
15 November 2024	<u>Supplement 1:</u> Report Reference: RR243270 dated 14 th November 2024. Description of the Change(s): Added 1/2 inch probes. Model code reconfigured. Other documentation updates not affecting the equipment safety.
15 April 2025	<u>Supplement 2:</u> Report Reference: RR245662 dated 14 April 2025. Description of the Changes: Updating company address and associated documentation changes.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

ANNEX

645S Series and TM100 Series Insertion

Description of Equipment:

a-bcde-f-g-h. Thermal Mass Gas Flow Meter and Temperature Transmitter (Insertion).

a = Model: 645S or TM100.

b = Probe length: 04, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35 or 36.

c = Retractor: I, R or C.

d = Crank retractor diameter: BLANK, 1 or 2.

e = Crank retractor flange: BLANK, A1, A2, A3, N1, N2, J1 or J2.

f = Sensor diameter and material: BLANK, H3, J3, L3, S2, H2, J2 or L2.

g = Display: D0 or DD.

h = Output: P1, BH or RS.

745S Series and TM100 Series Inline

Description of Equipment:

a-bcde-f-ghij-k-l-m. Thermal Mass Gas Flow Meter and Temperature Transmitter (Inline).

a = Model: 745S or TM100.

b = Flowbody size: 025, 05, 075, 10, 125, 15, 20, 25, 30, 40, 60 or 80.

c = Flowbody type: P, F, G, H, D, E, J or K.

d = Flowbody material: BLANK or C.

e = Flowbody conditioner: BLANK or X.

f = Flowbody pipe schedule: BLANK, S05, S10 or S80.

g = Retractor length: BLANK, 15, 18, 24, 30 or 36.

h = Retractor: BLANK, R or C.

i = Crank retractor diameter: BLANK, 1 or 2.

j = Crank retractor flange: BLANK, A1, A2, A3, N1, N2, J1 or J2.

k = Sensor diameter and material: BLANK, H3, J3, L3, S2, H2, J2 or L2.

l = Display: D0 or DD.

m = Output: P1, BH or RS.

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

Blueprint Report

Fox Thermal Instruments Inc 1000008198

Class No. 3615

Original Project I.D. 3052981

Certificate I.D. FM23ATEX0041X

<u>Drawing No.</u>	<u>Revision Level</u>	<u>Drawing Title</u>	<u>Last Report</u>
109629	D	BioTrak 645S/745S Instruction Manual	RR245662
109630	C	LABEL, SERIAL NUMBER, ELEX ENCL, 645S/745S SIERRA	RR245662
109643	C	CONFIGURATION DRAWING, INSERTION, MODEL 645S	RR243270
109644	C	CONFIGURATION DRAWING, INLINE, MODEL 745S	RR243270
110068	C	TM100 Thermal Mass Flow Meter Instruction Manual	RR245662